

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Satisfactory

Email Address(es): ppfeiffer@dadeschools.net;
wcabrera@dadeschools.net;
mwertz@dadeschools.net;
lpalacio@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair

At the time of this inspection, light bulbs out of service were observed in restroom girls second floor. Replace light bulbs.
CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #7. Heating, Ventilation, A/C Standards

At the time of this inspection, A/C vents with dust accumulation were observed in classroom 217. Clean and sanitize A/C vents.
CODE REFERENCE: 7. Heating, Ventilation, A/C Standards. 5(14)(b)(12) SREF. Heating/Ventilation/Air Conditioning systems shall be operational. The systems shall maintain design temperatures of at least 78° F in the summer and 68° F in the winter; and shall provide adequate humidity control. There shall be no signs of mold or mildew on carpet or walls in or around the HVAC system or toilet rooms. 5(16)(a) SREF. All occupied rooms and other rooms where odors or contaminants are generated shall be provided with ventilation.

Violation #12. Toilet Facilities

At the time of this inspection, two toilets out of service were observed in restroom girls 304. Repair or replace toilets.
CODE REFERENCE: 12. Toilet Facilities. 5(16)(b)2.c SREF. Deodorizers shall not be used in toilet rooms. 5(10)(f) SREF. Toilet and bath accessories, including grab bars; toilet paper dispensers; paper towel dispensers or hot-air drying devices; napkin disposal units; shelving, and mirrors, where provided, shall be maintained in a safe and secure condition at all times. The use of common or public towels shall not be permitted. 5(13)(f)4 SREF. Toilet facilities shall have a nonslip, impervious floor, impervious base, and minimum four foot- high impervious wainscot. 5(13)(p)2 SREF. Each staff toilet room shall be provided with at least one water closet and one lavatory and shall be provided with hot and cold water at the lavatory. 5(14)(b)10.a SREF. Walls in toilet rooms shall be finished with impervious materials to a minimum height of four feet. Floor and base in individual or group toilet rooms shall be impervious. 468.3.5.4 FBC. The entry to each group toilet room shall be provided with a door, partition, or other shielding device to block from view the occupants in the toilet room. If a door is provided, it shall have a closer. 5(16)(b)1 SREF. Toilet facilities shall be maintained in a satisfactory state of repair at all times. 5(16)(b)2.a. SREF. Water closets, urinals, lavatories, faucets, flush valves, dispensers, partitions, lower half of walls, and floors shall be maintained in a clean & sanitary condition at all times.

Inspection Conducted By: Yasdel MendezPerez (49962)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name:
Date: 3/4/2026

Inspector Signature:

Handwritten signature of Yasdel MendezPerez.

Client Signature:

Handwritten signature of the client.